


C Code : 16009  
 U Name :  
 S  
 T  
 O Address : Plant : Eastern Industrial Estate  
 M No 10 Soi G2, Pakomsongkrawhrat Rd.  
 E Huaypong, Muang, Rayong 21150  
 R Site :  
 Location : Return Line EHC  
 Test code : 894

Unit ID : 11 21 28MAX10BB001 RETURN LINE  
 Unit Type : Hyd Syst Power Turbine  
 Unit Make : ALSTOM  
 Unit Model : GT8C  
 Oil type / Viscosity : CASTROL HYPSPIN VG 32  
 Oil System Capacity :



**Notes (Finding, Evaluation, Interpretation, Suggestion and Recommendation)**

Components of dirt (silicon and/or aluminum) slightly above normal, however, no abrasive wear noted.  
 All other wear tests and oil condition tests appear satisfactory, and the oil was still serviceable at the time of sampling.  
 Continue routine sampling interval.

AS / Andy Sitton

			Current Sample			Previous Sample			Baseline and Alarm Limit								
Condition History			Wear	Oil	Cont.	Wear	Oil	Cont.	Wear	Oil	Cont.	Alarm Limit					
			(N)	(N)	(C)	(N)	(N)	(N)	(N)	(N)	(N)	B A S E L I N E	Alarm Limit Matrix -Set Name (Equipment type / oil type)				
													Hyd Syst Turbine Vickers Hyspin 32 (Glow)				
Lab ID													RDE fine				
Bottle ID													RFS coarse				
Date Sampled													The New Oil (TNO)				
Oil Hours (Kms)												U-Caution	U-Warning	U-Caution	U-Warning		
Unit Hours (Kms)																	
Oil Added (Liters)																	
Filters Hours (Kms)																	
Wear Condition			RDE fine		RFS coarse		RDE fine		RFS coarse		RDE fine		RFS coarse				
Wear Element	Method	Unit	RDE fine	RFS coarse	RDE fine	RFS coarse	RDE fine	RFS coarse	RDE fine	RFS coarse	The New Oil (TNO)	U-Caution	U-Warning	U-Caution	U-Warning		
Iron	D-6595	PPM	0.3	1.2	0.0	0.0	0.0	0.0	0.0	0.4	0	>1	>3	>5	>8		
Chromium	D-6595	PPM	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0	>1	>2	>1	>2		
Lead	D-6595	PPM	0.0	1.9	0.1	0.1	0.0	0.0	0.0	0.0	0	>2	>3	>5	>8		
Copper	D-6595	PPM	1.3	0.1	1.2	1.0	1.0	1.0	0.0	0.0	0	>6	>9	>1	>2		
Tin	D-6595	PPM	0.0	0.4	0.0	1.6	0.0	0.0	0.0	0.0	0	>1	>2	>4	>7		
Aluminum	D-6595	PPM	0.1	0.5	0.0	0.9	0.0	0.0	0.3	0.3	0	>1	>2	>1	>2		
Nickel	D-6595	PPM	0.0	0.0	0.0	0.4	0.0	0.0	0.0	0.0	0	>1	>2	>1	>2		
Silver	D-6595	PPM	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0						
Molybdenum	D-6595	PPM	0.0	0.4	0.0	0.5	0.0	0.0	0.0	0.0	0						
Titanium	D-6595	PPM	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0						
Oil Condition			RDE fine		RFS coarse		RDE fine		RFS coarse		TNO	L-Warning	L-Caution	U-Caution	U-Warning		
Viscosity @ 40°C	D-445	cSt	32.2		31.7		32.2				32.0	<28.8	<30.4	>33.6	>35.2		
Viscosity @ 100°C	D-445	cSt															
Oxidation	FTIR	Abs	3.3		3.3		4.1				4.6			>5.6	>6.6		
Nitration	FTIR	Abs	3.8		3.6		3.8				3.3			>4.3	>5.3		
TAN	D-974	mg KOH/g.	0.44		0.48		0.48				0.46			>0.66	>0.76		
TBN	D-4739	mg KOH/g.															
Contamination			RDE fine		RFS coarse		RDE fine		RFS coarse		TNO						
Water	T-H2O Check™	% (Wt.)	0.014		0.011		0.017				0.010			>0.05	>0.08		
Sodium	D-6595	PPM	0		0		0				0						
Silicon	D-6595	PPM	3.1 C	17.0 W	1.9	1.1	0.4	1.1			1	>3	>5	>3	>5		
Additive Element			RDE fine		RFS coarse		RDE fine		RFS coarse		TNO						
Boron	D-6595	PPM	0		0		0				0						
Magnesium	D-6595	PPM	0		0		0				0						
Calcium	D-6595	PPM	11		14		13				31						
Barium	D-6595	PPM	0		0		0				0						
Phosphorus	D-6595	PPM	235		253		247				332						
Zinc	D-6595	PPM	377	48	421	36	385	29			439						
Additional Test			RDE fine		RFS coarse		RDE fine		RFS coarse		TNO	U-Caution	U-Warning	U-Caution	U-Warning		
Flash Point	D-3828	°C															
Viscosity Index	D-2270																

Note: Alarm Limits are variable and dependent upon dataset size and to be used as general guideline.  
 No Sign or (N) : NORMAL, (C) or (C) : CAUTION (first level warning limit), (W) or (W) : Warning (second level warning limit)  
 U-Caution : Upper CAUTION Level, L-Caution : Lower CAUTION Level, First Level Alarm Alert Limit in Upper Level and/or Lower Level  
 U-Warning : Upper WARNING Level, L-Warning : Lower WARNING required Level, Second Level Alarm Alert Limit in Upper Level and/or Lower Level  
 Baseline will be data of either "The new oil" or "Reference oil" or "Oil specification". TNO = The new oil, RO = Reference oil, OS = Oil Specification  
 Accuracy of interpretation and recommendation are based on representatives sample and information supplied. No warranty is expressed or implied for this report.

C Code : **16009**

U S Name :

Address : Plant : Eastern Industrial Estate  
No 10 Soi G2, Pakomsongkrawhrat Rd.  
Huaypong, Muang, Rayong 21150

Site :

Location : Return Line EHC

Test code : 894

Unit ID : **11 21 28MAX10BB001 RETURN LINE**

Unit Type : Hyd Syst Power Turbine

Unit Make : ALSTOM

Unit Model : GT8C



Oil type / Viscosity : CASTROL HYPIN VG 32

Oil System Capacity :

**Notes (Finding, Evaluation, Interpretation, Suggestion and Recommendation)**


Particle count indicates oil cleanliness level is clean.

Lab ID	Current Sample		Previous Sample			Particle Count		Alarm Limit	
	Bottle ID	Date Sampled	148108	146305	NAS 1638	ISO 4406			
Oil Hours (Kms)	13684	12966	919600	12246	Hyd Syst Turbine Vickers Hypspin 32 (Glow)				
Unit Hours (Kms)	98501	97783	97063						
Oil Added (Liters)									
Filters Hours (Kms)									
Contamination						Particle Count			
Particle Count NAS 1638 System Standard						U-Warning		U-Warning	
Particle Size Range	No. of Particles / 100ml.	Class	No. of Particles / 100ml.	Class	No. of Particles / 100ml.	Class	Class	No. of Particles / 100ml.	Class
Particle Size 5-15 microns	15,400	6	10,200	6	6,400	5	6	>16000	7
Particle Size 15-25 microns	1,400	5	1,000	5	600	4	6	>2850	7
Particle Size 25-50 microns	400	6	200	6	100	5	6	>506	7
Particle Size 50-100 microns	<100	5	<100	5	<100	4	6	>1012	8
Particle Size >100 microns	<100	3	<100	2	<100	2	6		
Particle Count ISO 4406:1999 System Standard						Particle Count			
Particle Size Range	No. of Particles / ml.	Class	No. of Particles / ml.	Class	No. of Particles / ml.	Class	Class	No. of Particles / ml.	Class
Particle Size > 4 microns	461	16	307	15	192	15			
Particle Size > 6 microns	129	14	86	14	53	13			
Particle Size > 14 microns	18	11	12	11	7	10			
ISO 4406 Class Rating	16/14/11		15/14/11		15/13/10				




C Code : **16009**  
 U Name :  
 T Address : Plant : Eastern Industrial Estate  
 O No 10 Soi G2, Pakornsongkrawhrat Rd.  
 M Huaypong, Muang, Rayong 21150  
 E Site :  
 R Location : Return Line EHC  
 Test code : 894

E Unit ID : **11 21 28MAX10BB001 RETURN LINE**  
 O Unit Type : Hyd Syst Power Turbine  
 U Unit Make : ALSTOM  
 P Unit Model : GT8C  
 M Oil type / Viscosity : CASTROL HYPIN VG 32  
 E  
 N  
 L Oil System Capacity :



C Code : 16009  
 U Name :  
 S  
 T  
 O  
 M  
 E  
 R  
 Address : Plant : Eastern Industrial Estate  
 No 10 Soi G2, Pakornsongkrawhrat Rd.  
 Huaypong, Muang, Rayong 21150  
 Site :  
 Location : Return Line EHC  
 Test code : 894

E  
 O  
 U  
 I  
 P  
 M  
 E  
 N  
 T  
 Unit ID : 11 21 28MAX10BB001 RETURN LINE  
 Unit Type : Hyd Syst Power Turbine  
 Unit Make : ALSTOM  
 Unit Model : GT8C  
 Oil type / Viscosity : CASTROL HYPIN VG 32  
 Oil System Capacity :



C Code : **16009**  
 U Name :  
 T Address : Plant : Eastern Industrial Estate  
 O No 10 Soi G2, Pakornsongkrawhrat Rd.  
 M Huaypong, Muang, Rayong 21150  
 E Site :  
 R Location : Return Line EHC  
 Test code : 894

E Unit ID : **11 21 28MAX10BB001 RETURN LINE**  
 O Unit Type : Hyd Syst Power Turbine  
 U Unit Make : ALSTOM  
 I Unit Model : GT8C  
 P Oil type / Viscosity : CASTROL HYPIN VG 32  
 M  
 E  
 N  
 T  
 Oil System Capacity :

